

Laars Mighty Therm 2 Start Up Sheet

Test Date _____ Job Location _____

Model Number _____ Serial Number _____

Fuel Type _____

Check For Proper Start Up Sequence ☐

Blowers	☐	Low Water Cut Off	☐
Gas Valves	☐	Flow Switch	☐
Safety Valve	☐	Aquastat	☐
Gas Pressure Switches	☐	High Limit	☐
Ignitor(s)	☐	Smooth Ignition	☐
Bypass Operation	☐	Pump Operation	☐
Static Gas Inlet Pressure	☐	Proper Lockout Operation	☐
Firing Gas Inlet Pressure	☐	Carbon Dioxide %	☐
In. Press All Boilers Firing	☐	Oxygen %	☐
Gas Valve 1 Out Pressure	☐	Carbon Monoxide PPM	☐
Gas Valve 1A Out Pressure	☐	Stack Temperature °F	☐
Gas Valve 2 Out Pressure	☐	Combustion Efficiency %	☐
Gas Valve 3 Out Pressure	☐	Control Settings	
Gas Valve 3A Out Pressure	☐	Manual Reset High Limit	☐
Gas Valve 4 Out Pressure	☐	Auto High Limit	☐

NOTES: