SINGLE BOILER, PRIMARY/SECONDARY WITH 3-WAY VALVE



NOTES:

Primary/Secondary required for variable flow systems.
Boiler circuit piping must equal boiler flange size.
Primary (Boiler) Pump sized to boiler design flow requirements.
Boiler water connections (inlet/outlet) vary per model. Verify connection orientation.

All boilers furnished with factory mounted outlet water temperature gauge.
Dotted symbols indicate optional locations.
Primary (Boiler) pump requires system temp. interlock.
CWMU = Cold Water Make-Up
Temperature sensors require field interlock to boiler controls



MULTIPLE BOILERS, PRIMARY/SECONDARY WITH 3-WAY VALVE



NOTES:

Primary/Secondary required for variable flow systems.
Boiler circuit piping must equal boiler flange size.
Primary (Boiler) Pump sized to boiler design flow requirements.
Boiler water connections (inlet/outlet) vary per model. Verify connection orientation.

All boilers furnished with factory mounted outlet water temperature gauge.
Dotted symbols indicate optional locations.
Primary (Boiler) pump requires system temp. interlock.
CWMU = Cold Water Make-Up
Temperature sensors require field interlock to boiler controls



Litho in U.S.A. © Laars Heating Systems 0005